



CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Certificate No.: CE210304007160

Product

Fuse-disconnectors

Applicant

Zhejiang Benyi New Energy Co. Ltd.

Wenzhou Bridge Industrial Zone, Beibaixiang, Yueqing ,
Zhejiang Province, P.R.China

Type/Model

BR-30;

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2023CQC0304-014381, the submitted sample(s) of the above item complies with:

EN IEC 60947-3:2021

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Mar.05,2024

Valid until: Mar.04,2027

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE210304007160

BR-30

Ui: 1000V;

Uimp: 5kV;

Ith: 30A;

Ue: DC1000V;


Ie: 30A;

Iq: 15kA;

Utilization category: DC-20B;

IP20;

Connection diagram for DC:



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE